

## Quality Certificate of cement

Type of cement : **CEM I 42,5R**

Requirements acc. to: EN 197-1:2011

Values obtained for the period of: **November 2022**

	Unit	Results	Requirements acc. to: EN 197-1:2011
--	------	---------	--

### 1. Properties (by standards)

Compressive strength			
Early strength, after 2 days	MPa	26,8	≥ 20
Standard strength, after 28 days <small>(results from previous month)</small>	MPa	57,8	≥ 42,5 i ≤ 62,5
Initial setting time	min	170	≥ 60
Expansion of cement	mm	0,5	≤ 10
Sulfate content (as SO <sub>3</sub> )	%	3,31	≤ 4,0
Chloride content Cl <sup>-</sup>	%	0,090	≤ 0,10
Loss on ignition <sup>a)</sup>	%	3,23	≤ 5,0
Insoluble residues <sup>a)</sup>	%	0,80	≤ 5,0

### 2. Additional information

Laser particle size distribution passing 8 µm/32 µm	%	31/74	-
--	---	-------	---

a)only for CEM I and CEM III

*Anna Kozłowska*

Kierownik Jakości

*Anna Kozłowska*  
Cementownia Kujawy w Bielawach

.....  
stamp/signature