HOLCIM

Kujawy Cement Plant

Holcim Polska S.A.
Kujawy Cement Plant tel.: (52) 58 65 000, fax: (52) 58 65 011
Technical Support tel.: (41) 24 87 533, fax: (41) 24 87 531

Quality Certificate of cement

Type of cement : **CEM II/A-V 42,5R** **Requirements acc. to: EN 197-1:2011**

Values obtained for the period of: **October 2026**

	Unit	Results	Requirements acc. to: EN 197-1:2011
1.Properties (by standards)			
Compressive strength Early strength, after 2 days Standard strength, after 28 days (results from previous month)	 MPa MPa	 27,9 57,8	 ≥ 20 ≥ 42,5 i ≤ 62,5
Initial setting time	min	186	≥ 60
Expansion of cement	mm	0,6	≤10
Sulfate content (as SO_3)	%	3,12	≤ 4,0
Chloride content Cl^-	%	0,060	≤ 0,10
2. Additional information			
Laser particle size distribution passing 8 µm/32 µm	%	35/80	-

Anna Kozłowska
Kierownik Jakości
Cementownia Kujawy w Bielawach

.....
stamp/signature