

Quality Certificate of cement

Type of cement : **CEM II/A-V 42,5R**

Requirements acc. to: PN-EN 197-1:2012

Values obtained for the period of: **March**

2019

	Unit	Results	Requirements acc. to: PN-EN 197-1:2012
--	------	---------	---

1. Properties (by standards)

Compressive strength			
Early strength, after 2 days	MPa	24,1	≥ 20
Standard strength, after 28 days (results from previous month)	MPa	53,0	$\geq 42,5$ i $\leq 62,5$
Initial setting time	min	187	≥ 60
Expansion of cement	mm	0,5	≤ 10
Sulfate content (as SO ₃)	%	2,86	$\leq 4,0$
Chloride content Cl ⁻	%	0,066	$\leq 0,10$
Na ₂ O _{eq}	%	0,87	-
Loss on ignition ^{a)}	%	-	-
Insoluble residues ^{a)}	%	-	-
C ₃ A ^{b)}	%	-	-

2. Additional information

Specific surface area	cm ² /g	3815	-
-----------------------	--------------------	------	---

a) only for CEM I and CEM III

b) C₃A clinker calculated from chemical analysis acc. to Bogue, only for common cements resistant to sulphates „SR”

Kierownik Jakości

Jolanta Zdunowska

stamp/signature

LAFARGE
Budujemy
lepszé miasta™